

EU type examination certificate**EU-Baumusterprüfbescheinigung****CE-0085CT0184**Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Distributor <i>Vertreiber</i>	Ferrol S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Condensing combi water heater optional also as condensing water heater
Model <i>Modell</i>	LAMBORGHINI CALORECLIMA iXinox/IDOLA UI HYBRID...
Countries of Destination <i>Bestimmungsländer</i>	AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	supplement test: K 2107 2020 B20/E19 from 22.07.2020 (TRG) supplement test: K 2107 2020 B23/E22 from 23.07.2020 (TRG) supplement test: K 2107 2020 B26/E25 from 28.07.2020 (TRG) supplement test: K 2107 2020 B29/Z28 from 30.07.2020 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017)
Date of Expiry / File No. <i>Ablaufdatum / AZ</i>	06.07.2028 / 20-0463-GER

18.08.2020 Rie B-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
iXinox SMART 24 C	nominal heat output: 2,8...20,0 kW heat input (Hi): 2,9...20,4 (drinking water: ...25,0) kW	
IDOLA UI HYBRID H 08	nominal heat output: 2,8...24,0 kW heat input (Hi): 2,9...24,5 kW	
iXinox SMART 28 C; IDOLA UI HYBRID C 08	nominal heat output: 2,8...24,0 kW heat input (Hi): 2,9...24,5 (drinking water: ...28,5) kW	
iXinox SMART 34 C	nominal heat output: 2,8...30,0 kW heat input (Hi): 2,9...30,6 (drinking water: ...34,7) kW	
iXinox 18 H	nominal heat output: 4,9...18,0 kW heat input (Hi): 5,0...18,4 kW	
iXinox 24 C	nominal heat output: 4,9...20,0 kW heat input (Hi): 5,0...20,4 (drinking water: ...25,0) kW	
iXinox 28 C; iXinox 24 H; iXinox 28 K 50	nominal heat output: 4,9...24,0 kW heat input (Hi): 5,0...24,5 (drinking water: ...28,5) kW	
iXinox 34 C; iXinox 30 H; iXinox 34 K 50	nominal heat output: 6,3...30,0 kW heat input (Hi): 6,4...30,6 (drinking water: ...34,7) kW	
iXinox 45 H; iXinox 45 C	nominal heat output: 6,3...42,8 kW heat input (Hi): 6,4...43,8 (drinking water: ...43,8) kW	

Type Variation Ausführungsvariante	Explanations Erläuterungen
...C	condensing combi water heater
...H	condensing water heater
...K 50	with hot water storage tank (50 liters)
...SMART...	like ...C version only with decreased heat input

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

Flue types B23, B33, C13(x), C(10), C(11), C23, C33(x), C43(x), C53(x), C63(x), C83(x), C93(x): according to installation manual with flue system of Groppalli (2592-CPR-001)

Approved appliance categories, supply pressures and countries of destination:

I2N (20/25 mbar): BE, FR; I2N (20 mbar): CZ, ES, GR, PT, SI; I2E (20 mbar): LU, RO; I2H (20 mbar): FR, NL

I3B (37 mbar): ES, IE; I3B/P (30 mbar): BE; I3B/P (37 mbar): GR, PT

II2E3B/P (20, 30 mbar): PL; II2E3B/P (20, 50 mbar): AL, DE, MK, PL

II2H3B/P (20, 30 mbar): BG, CY, DK, EE, FI, HR, HU, IS, IT, LT, MT, NO, RO, SE, SI, SK, TR

II2H3B/P (20, 37 mbar): GR, HR, LV; II2H3B/P (20, 50 mbar): AT, CH, CY, CZ, LU

II2H3P (20, 37 mbar): ES, GB, IE, PT

II2H3+ (20, 30/37mbar): CH, CY, CZ, ES, GB, GR, IE, IT, PT, SI, SK, TR

II2ELL3B/P (20, 50 mbar): DE; II2E+3+ (20/25, 30/37 mbar): BE, FR

II2E+3P (20/25, 37 mbar): BE; II2E+3B/P (20/25, 37 mbar): FR; II2HS3B/P (25, 30 und 50 mbar): HU

II2HM3B/P (20, 30 mbar): IT; II2HM3+ (20, 30/37 mbar): IT

II2L3B/P (25, 30 mbar) and II2EK3B/P (20/25, 30 mbar): NL

II2ELw3B/P (20, 13, 30 mbar): PL

In the NON-EU countries the CE-marking will be accepted as conformity approval if the Gas Appliance Regulation EU/2016/426 is transferred into national law by this countries.

