

C € 0085



EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085CU0319

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) <i>EG-Wirkungsgradrichtlinie (92/42/EEG)</i>
Distributor <i>Vertreiber</i>	Ferrol S.p.A. Via Ritonda 78A, I-37047 San Bonifacio (VR)
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product description <i>Produktbezeichnung</i>	Wall hanging condensing boiler with integrated burner in modulating operation method and with enclosed combustion chamber
Model <i>Modell</i>	LAMBORGHINI CALORECLIMA IXINOX JET 24C; LAMBORGHINI CALORECLIMA ALHENA...
Type of Boiler <i>Heizkesseltyp</i>	condensing boiler
Test Reports <i>Prüfberichte</i>	Supplement test: K 2567 2025 E26_Rev.1 from 04.12.2025 (TRG) Supplement test: K 2567 2025 B28_Rev.1 from 04.12.2025 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
File Number <i>Aktenzeichen</i>	25-0201-GWR

70028-04-A-DE

18.12.2025 Pz B-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvgw-cert.com

Type Typ	Technical Data Technische Daten	Energy Labelling Energieeffizienzkennzeichnung
LAMBORGHINI CALORECLIMA IXINOX JET 24C; LAMBORGHINI CALORECLIMA ALHENA 24C	Nominal heat output: 4,1...20,0 kW Heat input (Hi): 4,2...20,6 (drinking water: ...25,0) kW	
LAMBORGHINI CALORECLIMA ALHENA 28C	Nominal heat output: 4,7...27,8 kW Heat input (Hi): 4,8...28,5 (drinking water: ...28,5) kW	
LAMBORGHINI CALORECLIMA ALHENA 34C	Nominal heat output: 4,8...34,0 kW Heat input (Hi): 5,0...34,8 (drinking water: ...34,8) kW	